

State of California
Department of Public Health
Water Treatment Device
Certificate Number

00 - 1426

Date Issued: March 14, 2005

Date Revised: June 2, 2008

Trademark/Model Designation

FM DWS 1500

Replacement Elements

47-5574704

Manufacturer: Cuno/Water Factory

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

Microbiological Contaminants and Turbidity

Cysts (protozoan)

Turbidity

Organic Contaminants

None

Inorganic/Radiological Contaminants

Lead

Asbestos

Rated Service Capacity: 1500 gallons

Rated Service Flow: 0.6 gpm

Conditions of Certification:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.